

TEMPORARY ASPHALT COLD MIX  
PATCH OR CONCRETE PAVEMENT  
(MATCH EXISTING MATERIAL,  
1.5X ADJACENT THICKNESS, "T")

SAWCUT

EXISTING PAVEMENT



FLOWABLE FILL


UNDISTURBED  
MATERIAL

MIRAFI N140 (OR  
APPROVED EQUAL)  
GEOTEXTILE FABRIC  
LINING ENTIRE TRENCH

6" MIN.

SIZE 67 ROCK  
BEDDING.  
MIN. 6" COVER.

WATER SERVICE LINE  
INSIDE CASING



PROFILE VIEW  
SECTION A-A

WATER SERVICE  
TRENCH REPAIR DETAIL

N.T.S.