

- BACKFILL AS SPECIFIED

PIPE PROTECTION COVER
(MIN. 12 INCHES, HAND PLACED AND HAND TAMPED,
IF MATERIAL IS FREE FROM ROCK GREATER THAN 1-1/2"
MECHANICAL METHODS MAY BE APPROVED)
SELECT MATERIAL - CLASS I, II, OR III*

BEDDING AND INITIAL BACKFILL
(MIN. 4 INCHES BELOW PIPE TO MIN. 4 INCHES
ABOVE PIPE, HAND PLACED AND CONSOLIDATED
BY HAND OR APPROVED MECHANCIAL METHODS)
COARSE AGGREGATE STANDARD SIZE NO. 67**

PVC PRESSURE WATER PIPE TRENCH

(STANDARD LAYING CONDITION "TYPE 5")

- * CLASS I, II, AND III AS DEFINED IN ASTM D2487 AND THE PIPE BACKFILL MATERIAL AND AGGREGATE BASE COURSE FILL SECTION OF THE SPECIFICATIONS
- ** STANDARD SIZE NO. 67 AS DEFINED IN ASTM D448, MAXIMUM EMBEDMENT PARTICLE SIZE SHALL NOT EXCEED 3/4 IN. FOR ANGULAR ROCK OR 1-1/2 IN. FOR ROUNDED ROCK

NOTE: SEE STANDARD DETAIL M-1, "TRACER WIRE CONNECTION PORT" FOR TRACER WIRE PORT SPACING



STANDARD DETAILS FOR WATER CONSTRUCTION

DRAWN BY: JSB DRA

DRAWING NO: S-49

DATE: SEPTEMBER, 2020