



ROD SCHEDULE		
SIZE	RODS PER FITTING	ROD DIA.
6"-8"	2	3/4"
12"	4	3/4"

NOTES:

1. THE ABOVE CONFIGURATION SHALL ONLY BE ALLOWED UNDER THE EXPRESSED WRITTEN APPROVAL OF THE S.W.U.
2. THE CONTRACTOR SHALL LOCATE EXISTING MAIN IN ADVANCE OF LAYING NEW LINE IN ORDER TO ASSURE ADEQUATE LENGTH TO ADJUST DEPTH OF NEW MAIN.
3. DIMENSIONS SHOWN ARE RECOMMENDED MINIMUMS TO PROVIDE ADEQUATE ROOM FOR TIGHTENING BOLTS ON JOINTS.
4. PROVIDE ALL THREAD STAINLESS STEEL TIE RODS WITH EYE BOLTS FOR ANCHORING ALL JOINTS.
5. ROTATE ELBOWS DOWN AS REQUIRED TO ALIGN WITH PIPE.
6. CONCRETE REACTION BACKING HAS BEEN REMOVED FROM DETAILS FOR CLARITY. REACTION SHALL BE PROVIDED AT ALL FITTINGS IN ACCORDANCE WITH THRUST BLOCKING DETAIL.

SWING CONNECTION-PROPOSED MAIN TO EXISTING MAIN

N.T.S.



STANDARD DETAILS  
FOR  
WATER AND SEWER CONSTRUCTION