


TEMPORARY ASPHALT COLD MIX
PATCH OR CONCRETE PAVEMENT
(MATCH EXISTING MATERIAL,
1.5X ADJACENT THICKNESS, "T")

SAWCUT

EXISTING PAVEMENT



FLOWABLE FILL


UNDISTURBED
MATERIAL

MIRAFI N140 (OR
APPROVED EQUAL)
GEOTEXTILE FABRIC
LINING ENTIRE TRENCH

6" MIN.

SIZE 67 ROCK
BEDDING.
MIN. 6" COVER.

WATER SERVICE LINE
INSIDE CASING



PROFILE VIEW
SECTION A-A

WATER SERVICE
TRENCH REPAIR DETAIL

N.T.S.